
Document in original language | $333548 \cdot v02$







© Copyright Systemair UAB
All rights reserved
E&OE
Systemair UAB reserves the rights to change their products without notice.
This also applies to products already ordered, as long as it does not affect the previously agreed specifications.



Contents

1	Overv	iew		1
	1.1		Description	
	1.2		y _.	
_	1.3		el	
2		_		
3				
	3.1		GHT control panel	
		3.1.1	Indicators	2
		3.1.2 3.1.3	To select airflow level	
		3.1.3	To reset the filter change	3
		3.1.4	time	3
		3.1.5	To change control panel	
			address (if more than one control	
			panel is used)	3
	3.2		UCH control panel / SAVE	
			Т	
		3.2.1	Common symbols	
		3.2.2	Home screen overview	
		3.2.3 3.2.4	Status bar and alarms	
		3.2.4	To select user mode	
		3.2.5	To change the	
		5.2.0	temperature	7
		3.2.7	To change the airflow	
		3.2.8	To set a week schedule	
4	Maint	enance		9
	4.1		ance Schedule	
	4.2		s internal components	
	4.3		the air chambers	
	4.4		ge filters	10
		4.4.1	To reset the filter change	11
		4.4.2	time To select a different filter	1 1
		4.4.2	kit	11
	4.5	To clean	the heat exchanger	
	4.6	To clean	fans	12
	4.7	To replac	ce the rotor drive belt	13
	4.8	Duct Sys	tem Maintenance	14
		4.8.1	Cleaning extract louvres and	
			supply air diffusers	14

	4.8.2	Checking the outdoor air	
		intake	14
	4.8.3	Checking the roof cowl (if	
		fitted)	14
	4.8.4	Checking and cleaning the	
		duct system	14
5	Troubleshootin	ng	15
5	Electrical data.	-	16
7	Disposal and re	ecyclina	16

1 Overview

1.1 General Description

This manual describes basic information how to operate and perform maintenance on the unit and the system it is connected to.

Read the instructions carefully and in its entirety.

For description of advanced settings and installation of accessories see Service and Accessories Installation manual.

All documents can be found in our online catalogue at www.systemair.com.

1.2 Warranty

For the assertion of warranty claims, the products must be correctly connected and operated, and used in accordance with the data sheets. Further prerequisites are a completed maintenance plan with no gaps and a commissioning report. Systemair will require these in the case of a warranty claim.

1.3 Type label

Before calling your service representative, make a note of the specification and production number from the type label, which can be found next to the external connections and inside of the unit.




Fig. 1 Type label

Position	Description
1	Product code (product specification)
2	Product item number
3	Production order number
4	Serial number
5	Production date (YY.MM.DD)
6	Scannable code for manufacturing order (MO) number and software version
7	Scannable code for the spare parts list and documentation

2 Warnings



Danger

- Make sure that the mains supply to the unit is disconnected before performing any maintenance or electrical work!
- All electrical connections and maintenance work must be carried out by an authorized installer and in accordance with local rules and regulations.



Warning

- This product is not intended to be used by children or people with reduced physical or mental ability or lack of experience and knowledge, if no instruction concerning the use has been given by the person responsible for their safety or that this person is supervising the operation. Children should be supervised so that they can not play with the product.
- Beware of sharp edges during mounting and maintenance. Use protective gloves.



Warning

Although the mains supply to the unit has been disconnected there is still a risk of injury due to rotating
parts that have not come to a complete standstill.

3 Operation

The unit can be controlled by one or more control methods:

- · SAVE LIGHT control panel, refer to 2.
- SAVE TOUCH control panel, refer to 4.
- · SAVE CONNECT, refer to 4.

3.1 SAVE LIGHT control panel

SAVE LIGHT is a basic control panel for SAVE series residential air handling units. SAVE LIGHT allows to change airflow levels and indicates when any alarm is present.

- 1. A button to increase airflow
- 2. A button to reduce airflow
- 3. Current airflow level/mode
- 4. Filter change LED
- 5. General alarm LED




Fig. 2 Explanation of symbols

3.1.1 Indicators



General alarm LED shows when any alarm has occurred. Alarm type is not specified. It is not possible to acknowledge alarms from the SAVE LIGHT control panel. Please check SAVE TOUCH control panel or contact your local technical service provider.



The filter change LED shows when filters have to be replaced.

Filters cannot be cleaned and must be changed as necessary. This is normally done 2–3 times per year depending on the air pollution at the installation site.

3.1.2 To select airflow level

LEDs show current airflow level (figure 2, pos. 3).

- Press + button to increase the airflow.
- Press button to decrease the airflow.

Off	Low (Minimum)	Normal	High	Refresh (Maximum)	Auto — flashing slowly
0 0 0			© •		
The fan can be set to Off by activating Manual Fan Stop function in Service menu.	Fan speed – 25%	Fan speed – 45%	Fan speed – 70%	Sets speed of both supply and extract air fans to Maximum levels to replace indoor air with a fresh air in a short period of time. The unit returns to previously active mode after 1 hour when in the Refresh mode.	Automatic airflow control. Available only when Week Schedule, Demand Control functions are active or Fan Control setting is set to External.



Note:

- Minimum and Maximum airflow can only be activated by a signal from an external source.
- Auto mode or Manual Fan Stop function can be enabled using the SAVE TOUCH control panel or a mobile application.
- It is **not** recommended to set fan to Off in standard households. If manual fan stop is activated, the unit should be provided with dampers in exhaust and fresh air ducts to avoid cold draught and risk of condensation when the unit has been stopped.

3.1.3 To cancel sleep mode

Press any button to cancel the sleep mode. SAVE LIGHT returns to the sleep mode after 3 minutes of inactivity.

All control panel lights are off during sleep mode. The sleep mode is active from 9:00 PM to 7:00 AM (based on time of the air handling unit).

3.1.4 To reset the filter change time

Push and hold \bigoplus and \bigoplus buttons for 3 seconds to reset the filter timer (filter change LED will turn off).

3.1.5 To change control panel address (if more than one control panel is used)

If more than one SAVE LIGHT control panel is used, the address of other control panels must be changed.

Each control panel must have it's own unique address number. No control panel should have the same address value to function properly.

- 1. Push and hold \bigcirc button for 10 seconds to see a current control panel address value.
- 2. Press \bigoplus button to increase and \bigoplus button decrease the value.

Address value can be changed from 6 to 10, default value is 10.

Address value	Indication
6	Low airflow LED is on
7	Normal airflow LEDs are on
8	High airflow LEDs are on
9	Refresh mode LEDs are on
10	All LEDs are on



3.2 SAVE TOUCH control panel / SAVE CONNECT

Settings are done by touching the icons or options. The touch screen is sensitive and it is not necessary to press too hard.

SAVE CONNECT solution (mobile application and Internet access module) has a similar menu structure and functionality as SAVE TOUCH control panel, so this section can also be used as a quide for the mobile application.

3.2.1 Common symbols

The following selection symbols are common and are present in most menu pages:



Back button to return to a previous menu, located at the upper left corner



On and Off slider to activate or deactivate a function. White bubble — function is inactive, green bubble — function is active.



Up arrow to increase a value

CANCEL

Button to cancel changes



Down arrow to decrease a value

SET/OK


Buttons to confirm changes

Some menus have more than one page. Touch page indicator in the top right corner to go to the next page. The first number indicates current page number and the second number indicates a total number of pages available.

Many options show up in a form of the pop-up window. Select the option from the displayed list in the pop-up window and press ox to confirm selection.

3.2.2 Home screen overview

- 1. Menu
- 2. Active user mode
- 3. Temperature settings
- 4. Airflow settings
- 5. Alarms and warnings
- 6. Status line
- 7. Outdoor temperature



- A. Return to home screen
- B. Basic read-only information about the unit
- C. Currently active alarms and alarm history
- D. Configure and check week schedule
- E. Check and change remaining time till filter change
- F. General system preferences
- G. Configuration of all system parameters
- H. Help and troubleshooting menu


3.2.3 Status bar and alarms

Status bar indicates all currently active functions. Touch the status bar to see descriptions of active functions in more detail.



For more information about user modes and functions, please check Help menu.

Touch the alarm bar on the home screen to see all active alarms.



Touch HELP button to know more about the alarm. To clear the alarm, touch ACKNOWLEDGE button.



Note:

The underlying cause of the alarm must be resolved first otherwise the alarm will appear again. If the problem continues contact your installation company or place of purchase.


3.2.4 Quick Information screen

Quick information screen can be shown instead of a sleep mode screen.

Quick information screen shows the following information:

- 1. Time
- 2. Outdoor temperature
- 3. Current User mode / Alarm
- 4. Fan speed
 - ooo off, •oo Minimum/Low, ••o Normal, ••• - High/Maximum
- 5. Supply air temperature
- 6. Relative humidity (if configured)
- 7. CO₂ sensor value (if configured)

Quick Information screen can be enabled or disabled in menu System Preferences -> Display Settings -> Quick Info screen.




3.2.5 To select user mode



For more information about user modes and functions, please check ${\tt Help}$ menu.

The top circle on the home screen indicates a currently active user mode. Touch the symbol to change the mode.



Duration have to be set for temporary user modes. SAVE VSR 300/500 will return to its previous working mode after the set time expires.



Note:

AUTO mode is available for selection only if the optional Demand Control, Week Schedule and/or external fan control functions are activated.

3.2.5.1 Permanent modes

Permanent modes are always active unless interrupted by temporary modes, activated user functions or alarms:

lcon	Text	Description
AUTO	Auto	Automatic airflow control. AUTO mode is available for selection when Demand Control, Week Schedule and/or external fan control functions are configured, otherwise AUTO mode icon won't be visible in active user modes menu. AUTO mode activates Demand Control, Week Schedule and/or external fan control functions. Demand is available to choose as airflow setting in Week Schedule.
		Manual selection of airflow levels. The unit can be set run at one out of four available airflow speeds: $Off/Low/Normal/High$.
	Manual	Note:
		The fan can be set to OFF by activating Manual Fan Stop function in Service menu.

3.2.5.2 Temporary modes

Temporary modes are active only for a set period of time unless interrupted by active user modes, activated user functions or alarms:


Icon	Text	Description
	Holiday	Sets speed of both supply and extract air fans to Low levels when user is away from home for a long period of time. ECO mode is active. Set duration in days.
	Crowded	Sets speed of both supply and extract air fans to maximum High levels and temperature setpoint offset to –3 K when apartment is more crowded than usual. Default temperature setpoint offset is –3 K. Set duration in hours.
於	Away	Sets speed of both supply and extract air fans to Low levels when user is away from home for a short period of time. ECO mode is active. Set duration in hours.

Icon	Text	Description
MAX	Refresh	Sets speed of both supply and extract air fans to Maximum levels to replace indoor air with a fresh air in a short period of time. Set duration in minutes.
	Fireplace	Sets speed of supply air fan to High level and extract air fan to Low level to increase air pressure within the apartment for better smoke extraction through the chimney. Set duration in minutes.


Settings of all modes can be modified in Service menu.

3.2.6 To change the temperature

Touch the thermometer symbol on the home screen to open the temperature settings window.




Use up and down arrows to increase or decrease a value. The default setting is 18 °C.



 ${\tt ECO}\ {\tt mode}$ is a power saving function which partially limits heater operation and can only be activated if a heater is installed.

3.2.7 To change the airflow

Touch the fan symbol on the home screen. In the open window use up or down arrows to increase or decrease the speed of fans.





Note:


Airflow regulation is available only in Manual mode.




3.2.8 To set a week schedule

While in home screen, touch menu icon and select Week Schedule.

The menu is locked by default. Enter a password (default password is 1111).



Touch icon at the bottom left corner of the screen to add a new schedule or press EDIT button to modify already added schedule.



Touch the slider to the right to activate scheduled period.

Set the time. Touch the START TIME or END TIME values to change time. Use arrow buttons \wedge and \vee to increase or decrease value. Confirm with ok button.



Note:

Scheduled time can start but never end at midnight (00:00). The latest END TIME period is 23:59. Scheduled time cannot go to the next day.

12 or 24 hour time format can be changed in System Preferences menu.

Week Schedule is active only during AUTO mode.

If necessary, activate second scheduled period and set up time.


Once time is set, click on the day(s) when schedule should be active. It is possible to set a separate schedule for each day. Already scheduled days are not available for selection for new schedules.

Confirm schedule with ox button.

3.2.8.1 To schedule airflow settings

Touch settings icon to go to SCHEDULE AIRFLOW SETTINGS menu. In this menu set airflow level for scheduled and unscheduled periods. Available levels: Off, Low, Normal, High or Demand.

Set temperature setpoint offset for both periods (-10°C – 0°C).



Demand level is available only if Demand Control or External fan function is active.

4 Maintenance



Danger

 Make sure that the mains supply to the unit is disconnected before performing any maintenance or electrical work!

Warranty claims can only be made if maintenance work is carried out correctly and written evidence thereof is provided.

4.1 Maintenance Schedule

Task	6 months	1 year	3 years	When necessary
General inspection	X			
Filter change	X			X
Fan cleaning		X		
Heat exchanger cleaning			X	X
Belt replacement				X
Checking and cleaning louvres/ diffusers				X
Checking and cleaning outdoor air intake	X			
Checking and cleaning roof cowl (if fitted)	X			
Cleaning of duct system				X 1

^{1.} It is recommended to do this every 5 years and is normally carried out by authorized companies specialized in this area.

- Use original spare parts from Systemair only.
- Scan the code on the type label to find a spare part list.

4.2 To access internal components



Danger

 Make sure that the Mains supply to the unit is disconnected before performing any maintenance or electrical work!

Loosen the four knobs and loosen the Philips screw to open the side cover.




Fig. 3 Open the side cover

4.3 To clean the air chambers



Danger

 Make sure that the Mains supply to the unit is disconnected before performing any maintenance or electrical work!

Dust and dirt collect in the air chambers inside the product. The product must be cleaned periodically.


- 1. Stop the unit by disconnecting the mains.
- 2. Open and remove the side cover. See chapter 4.2.
- 3. Clean any dust or dirt. Use a vacuum cleaner and a damp cloth. Allow the product to dry.
- 4. Replace and lock the side cover and connect the unit to mains.

4.4 To change filters

The filters cannot be cleaned and must be changed as necessary. This is normally done 1–2 times per year depending on the air pollution at the installation site.

It is very important to change filters regularly for performance and energy efficiency of the unit.

Each filter has a label with an part number for identification. Provide this number when ordering new filters.



When it's time to change the filters an alarm is shown on the control panel display. When this occurs do the following:

- 1. Stop the unit by disconnecting the mains.
- 2. Open and remove the side cover. See chapter 4.2.
- 3. Pull out the filters towards you. Some force may be needed.
- 4. Insert the new filters. Make sure that the correct filter types are inserted. See note above.
- 5. Replace and lock the side cover and connect the unit to mains.



6. Reset the filter time. See chapter 4.4.1.

4.4.1 To reset the filter change time


Once filter is changed, it is necessary to reset filter time. Go to Filter menu (see 3.2.2 Home screen overview, page 4, pos. E) or if filter alarm is present, click on alarm status line (see 3.2.2 Home screen overview, page 4, pos. 5) and select filter alarm. Select CHANGE FILTER, in the pop up menu define a new filter period and press ok to confirm selection.

Filter time is now reset.



Note:

The menu is locked by default. Enter a password (default password is 1111).




4.4.2 To select a different filter kit

Standard filters are designed for good outdoor air quality. It is possible to select and order filter kits for poorer air quality environment.

To change filter kit type

- 1. Touch Select different filter kit button in the alarm menu.

 Alternatively, go to Filter menu (3.2.2 *Home screen overview*, page 4, pos. E).
- 2. Select filter kit from the list.
- 3. Touch ox button.



4.5 To clean the heat exchanger



Danger

 Make sure that the Mains supply to the unit is disconnected before performing any maintenance or electrical work!



Warning

- Risk of personal injury! The heat exchanger weighs about 14 kg. There is a risk that the heat exchanger falls out of the unit.
- · Make sure that small children are not beneath the unit when the heat exchanger is removed!



Warning

• Beware of sharp edges during mounting and maintenance. Use protective gloves.

Even if the required maintenance is carried out, dust will build up in the exchanger block. It is therefore of vital importance for the upkeep of a high efficiency that the exchanger block is removed from the unit and cleaned periodically as described below. Clean the heat exchanger at least every 3 years or when required.



- 1. Stop the unit by disconnecting the mains.
- 2. Open and remove the side cover. See figure 4.2.
- 3. Disconnect the rotor power supply and the rotor sensor. Both cables are found beside the rotor.
- 4. Loosen mounting screws at the bottom (1).



Note:

In VSR 500 unit the mounting screws are located at the top.

- 5. Pull out the rotor towards you. Some force may be needed.
- 6. Clean the rotor.


Wash in hot soapy water. Do not use detergent containing ammonia. Rinse using, for instance, a shower handle or carefully with compressed air.



Warning

Ensure the rotor motor is not exposed to moisture

- 7. Remount the rotor. Don't forget to reconnect the rotor power and sensor cables.
- 8. Replace and lock the side cover and connect the unit to mains.



4.6 To clean fans



Danger

 Make sure that the mains supply to the unit is disconnected before performing any maintenance or electrical work!



Warning

• Risk of injury due to rotating parts that have not come to a complete standstill after mains supply to the unit have been disconnected.



Warning

· Beware of sharp edges during mounting and maintenance. Use protective gloves.



The motor bearings are life time lubricated and maintenance free.

Even if the required maintenance, such as changing of filters is carried out, dust and grease may slowly build up inside the fans. This will reduce the efficiency.

The fans may be cleaned as illustrated in below procedure.





Fig. 4 Extract and supply air fans

- 1. Stop the unit by disconnecting the mains.
- 2. Open and remove the side cover. See chapter 4.2.
- 3. Disconnect the fan power cables. The cables are found beside the fans.
- 4. Loosen the mounting screws (1) and pull the fans towards you. Some force may be needed.
- Clean the fans with a cloth or a soft brush. Do not use water. White spirit can be used to remove obstinate deposits.

Allow the fans to dry properly before remounting.



- 6. Remount the fans. Don't forget to reconnect the fan power cables.
- 7. Replace and lock the side cover and connect the unit to mains.

4.7 To replace the rotor drive belt




Danger


 Make sure that the Mains supply to the unit is disconnected before performing any maintenance or electrical work!

If the alarm Rotor guard is raised the rotor drive belt may be damaged or broken, see chapter 3.2.3.

A spare drive belt is already placed on the heat exchanger rotor and delivered with the unit.







In case both welded belts break it is possible to use joint nipple as a temporarily quick repair solution until the welded belt can be replaced with a new one. Depending of how the unit is installed, it may be not necessary to remove the heat exchanger package in order to temporary repair a broken drive belt if the belt pulley can be accessed.

Temporary belt repair solution

- 1. Stop the unit by disconnecting the mains.
- 2. Open and remove the side cover. See chapter 4.2.
- 3. Remove the broken drive belt.
- 4. Use tape to attach the drive belt to the rotating heat exchanger, and rotate the exchanger by hand to get hold of the drive belt.
- 5. Remove the tape and put the "empty" end on to the nipple. Press the ends firmly towards each other and tighten the nipple.
- 6. Pull the drive belt on to the belt pulley and rotate the exchanger by hand. Check that the belt pulley rotates.



If the drive belt slips, the drive belt may be too long and needs to be shortened. Cut the drive belt 5 mm and go to step 5.

- 7. Replace and lock the side cover and connect the unit to mains.
- 8. Check that the alarm has ceased on the Control Display.



If the alarm remains, contact the installer.

4.8 **Duct System Maintenance**

4.8.1 Cleaning extract louvres and supply air diffusers

The system supplies fresh air to your home and extracts the used indoor air via the duct system and diffusers/louvres. Diffusers and louvres are mounted in ceilings/walls in bedrooms, living room, wet rooms, WC etc. Remove diffusers and louvres and wash in hot soapy water as required (diffusers/louvres must not be exchanged). Cleaning of diffusers/ louvres can be done as necessary.

Checking the outdoor air intake 4.8.2

Leaves and pollution could plug up the air intake grille and reduce the capacity. Check the air intake grille, and clean as necessary. It is recommended to do this at least twice a year.

Checking the roof cowl (if fitted) 4.8.3

The roof cowl (if fitted) connected to the exhaust air duct needs to be checked at least twice a year and cleaned if necessary.

4.8.4 Checking and cleaning the duct system

Dust and grease deposits may build up in the duct system, even if required maintenance such as changing of filters is being carried out. This will reduce the efficiency of the installation.



The duct runs should therefore be cleaned/changed when necessary. Steel ducts can be cleaned by pulling a brush soaked in hot soapy water through the duct via diffuser/louvre openings or special inspection hatches in the duct system (if fitted).

It is recommended to do this every 5 years and is normally carried out by authorized companies specialized in this area.

5 Troubleshooting

If problems should occur, please check the items below before calling your service representative.

Fans do not start

- 1. Check the control panel for alarms.
- 2. Check that all fuses and fast couplings are connected (main power supply and fast couplings for supply and extract air fans).
- 3. Check the week schedule. Fans may be set to OFF in the Schedule airflow settings menu.

Reduced airflow

- 1. Check the control panel for alarms. Some alarms can reduce the airflow to LOW if active.
- 2. The unit could be in defrost mode. This reduces the fan speed and in some cases shuts down the supply air fan completely during the defrosting cycle. The fans go back to normal after defrosting. There should be a defrosting function icon visible on the home screen if defrosting is active.
- 3. Speed of fans is linearly reduced when the outdoor air temperature is below 0°C and an outdoor airflow compensation function is enabled.
- 4. Check if temporary user mode that reduces airflow is not activated, for example Away, Holiday, etc. Also check digital inputs Central Vacuum Cleaner and Cooker Hood.
- 5. Check the airflow settings in the control panel.
- 6. Check week schedule settings (chapter 3.2.8).
- 7. Check filters. Is change of filters required?
- 8. Check diffusers/louvres. Is cleaning of diffusers/louvres required?
- 9. Check fans and heat exchange block. Is cleaning required?
- 10. Check if the buildings air intake and roof unit (exhaust) have been clogged.
- 11. Check visible duct runs for damage and/or build up of dust/pollution.
- 12. Check diffuser/louvre openings.

The unit cannot be controlled (control functions are stuck

- 1. Reset control functions by disconnecting mains power for at least 10 seconds.
- 2. Check the modular contact connection between the control panel and the main printed circuit board.

Low supply air temperature

- 1. Check the control panel for alarms.
- 2. Check the active user functions on the control panel if defrosting function is running.
- 3. Check set supply air temperature on the control panel.
- 4. Check if Eco mode is activated on the control panel (it is a power saving function and prevents the heater from activating).
- 5. Check if user modes Holiday, Away or Crowded are activated on the control panel or via a hardwired switch.
- 6. Check the analogue inputs in the service menu to verify that the temperature sensors are functioning correctly.
- 7. In case of installed electrical/other re-heater battery: Check if the overheat protection thermostat is still active. If necessary, reset by pressing the red button on the front plate of the electrical re-heater.
- 8. Check if the extract filter must be changed.
- 9. Check if the unit has a re-heater battery connected. At very cold outdoor conditions an electrical or water heating battery might be necessary. A re-heater battery can be acquired as an accessory.

Noise/vibrations

- 1. Clean fan impellers.
- 2. Check that the screws holding the fans are tightened.



- - 3. Check that the anti vibration lists are fitted to the mounting bracket and to the back of the unit.
 - 4. Check that the rotor belt is not slipping if the unit has rotating heat exchanger.

Electrical data 6

Model	VSR300	VSR500	
Re-heater	1670 W		
Fans	166 W	338 W	
Total power consumption	1836 W	2008 W	
Fuse	10 A	13 A	

Voltage 230V 1~, 50Hz

Disposal and recycling 7



This product is compliant with the European WEEE Directive and related national waste legislation. When disposing the unit, follow your local rules and regulations. This product packing materials are recyclable and can be reused. Do not dispose in household waste.





Systemair UAB Linų st. 101 LT–20174 Ukmergė, LITHUANIA

Phone +370 340 60165 Fax +370 340 60166